

...412 67 / 23 1 60

103 7109

TO E.S. AAJVS P/B, E.E [PPS W] ELE P/B
INF DIRECTOR TW P/B
FM SW O/S D/CREEK

16-5

166 6/10/99

= BOTH THE D.G STS OF 24 KW AND 18 KW ARE OUT OF ORDER FROM 1/10/99[.]
POWER SUPPLY COMPLETELY STOPED. TECHNICIAN FROM HUT BAY REACHED AND LEFT
D/C ON 6/10/99 WITHOUT RESTORING POWER SUPPLY. REQUEST TO DO THE NEEDFU
L. SBEO ALSO LEFT TO HUT BAY TODAY . FOR INFO PSE=

1630

MAB...

ARRIVS

1. R.C. No: 1308
2. Date: 8/7/99
3. To Whom Marked: S.A.
4. Remarks:
5. Initials of E.S.:
\$

S.A. / Sent Signy
to NE
Sect H/B
to a/b

000841