

9/20

16-5

1. R. NO:	1330
2. Date:	15/10
3. To Whom Marked:	Sub
4. Remarks:	
5. Initials:	

104

K42/N60 DE N67 Z3/Z 2 50

TO. ES AAJVS P/B (R) A.E POWER HOUSE H/BAY
INFO. EE (PPS&W) P/B , DIR. (TW) P/B
FM. S.W O/S DC/REEK.

175 13/X/99

= ROS NO. 166 DTD 6/X/99 () TECHNICIAN REACHED D/CREEK ON 12/10/99 () 18
KW DG SET WAS REPAIRED AND RESUMED POWER SUPPLY FROM TODAY IT SELF () PARA
() 5 NOS. TUBE LIGHT ALSO REPLACED AND PROVIDED NEW () PARTY LEFT D/CREEK
TODAY MORNING () FOR KIND INFO. PSE =

07557144

1630..

QSP BY N67

ERC...

END
\$P

MSG NO : 015

CA
1511939