

R002 18/01/20 15:14:11

TKS A42 DE A60 Z2 NR13 GR68

TO : EE PPS&W P/BLAIR
INF : ES AAJVS P/BLAIR
FM : G V HUTBAY

AAJVS	
1. R. D. No.:	2001
2. Date:	20/1/2000
3. To Whom Marked:	
4. Demos:	
5. Initials:	

9843

113

00

NO - 09 18/01/2000

= SELF ALONGWITH E/FITTER VISITED SOUTHBAY POWER HOUSE ON 14/1/2000 FO
UND LINK BELT DAMAGED AND HEAVY LEAKAGE IN RADIATOR OF 7.5 KVA KIRLOSKAR D
G SET () COMPOUNDING TRANSFORMER OF THE SAME SET FITTED WITH 7.5 KVA PARRY
MAKE D.G SET AND RESUMED POWER SUPPLY =

SD BY ASHOK

THI 1415

....

5/17
29/1/2000

TOR 88k
15/4/18