

6385

\$

001 20/09/00 07:03:06

Z3/Z

1544/011712
20/9/2000

88

151

K42 DE N67

TO S.E. [ELEC.] P/B
INF A.E. ELE. HUTBAY [R] E.S.AAJVS P/B [R] DIR. [TW] P/B
FM S.W D/CREEK

NO.91 DT 19/9/2K

= A.E.E.ECTRIC HUTBAY INTIMATED TO E.E. ELE. [PPSW] P/B REQUESTED TO SEND RUBBER DIAFRAM COUPLING FOR 18 KW DG SET VIDE SIGNAL NO.786 DTD 7/9/2K [.] POWER SUPPLY SUSPENDED SINCE 16/9/2K [.] FOR AE HUTBAY ONLY [.] REQUEST TO ARRANGE TO DEPUTE MECHANIC AT THE EARLIEST TO RECTIFY THE FAULT OF 24 KW DG SET [.] SOLAR POWER PLANT COULD NOT FUNCTION PROPERLY DUE TO SHORTAGE OF D/WATER [.] REQUEST TAKE FAVOURABLE ACTION IMMEDIATELY [.] MMU =

THI 1540
SD/KKJ QSP BY N60

RESCAUS
NA

20/9/2000

Stamp: A.I.V.S.

1. R. D. No:

2. Date:

3. To Whom Marked:

4. Remarks:

5. Initials of E.S.:

TOR 110
0703/20