

R031 14/04/01 01:35:58

TKS 142 A60 DE A67

Z2/Z

NR02

GR50

TO : AE ELE HUTRAY
INF : ES AAJVS DIR TW PB
FM : P IC D/CREEK

NO - 193 14/4/2001

18h

904

AAJVS

1. R. D. No : 91
2. Date : 16/4/01
3. To Whom Marked :
4. Remarks :
5. Initials of E :

= 24 KW DG SET COULD NOT BE OPERATED YESTERDAY NIGHT DISCOUPLING
DIAPHRAM DAMAGED () KINDLY ARRANGE TO SEND MECHANIC WITH SPARE
PARTS TO RESTORE POWER SUPPLY () FOR KIND INFO. & NA PSE =

SD BY ASHOK

THI 1600

* RELAYED BY A60 *

SA 135/000
14/4
[Signature]