

R031 14/04/01 01:35:58

TKS A42 A60 DE A67

22/Z

NR02

BR50

TO : AE ELE HUTBAY
INF : ES AAJVS , DIR TW PE
FM : P IC D/CREEK

NO - 193 14/4/2001

= 24 KW DG SET COULD NOT BE OPERATED YESTERDAY NIGHT DISCOUPLING
DIAPHRAM DAMAGED () KINDLY ARRANGE TO SEND MECHANIC WITH SPARE
PARTS TO RESTORE POWER SUPPLY () FOR KIND INFO. & NA PSE =

SD BY ASHOK

THI 1600

* RELAYE

673/DIR TW
18/04/01

16-5

For immediate action
ga
18/4

ESU/asm

9041/3

190 IVS

1. R. D. No: 120
2. Date: 18/4/2001
3. To Whom Marked: SA
4. Remarks:
5. Initials of ES:

SA
1735/PA
14/4