

6345/2

Sign

Letter sent to
SE. Electricals. Please
link this in command
file

SA (SB) 18 comp
9/11/98

R077 08/11/98 06:14:41

TKS A42 A60 DE A67 Z/Z2 NR02 GR30

TO : G.V HUTBAY
INF : ES AAJVS P/BLAIR, TEHSILDAR L/ANDAMAN
FM : S.W OS D/CREEK

NO - 244 7/11/98

= SBEO REPORTED D/CREEK TODAY AND REPORTED THAT D.G SET COULD NOT BE
OPERATED DUE TO LEAKAGE IN RADIATOR =

THI-1600
RECD BY ASHOK

Ton 0618/08/11

AATVS	
R. D. No :	649
Date :	9/11/98
3. To Whom Marked :	S
4. Remarks :	
5. Initials of ES :	