

POLE SCHEDULE

416

Sl. No	Span Length	GI Pipe pole 09 Mtrs	LT X ARM	LT Shackle insulator	LT Shackle Hardware Nut Bolt 5"	Stay set LT	Guy Insulator	Stay Wire	Nuts & Bolts 5"	Cable 25 Sq.mn ABC (3, 4, 5)	MS Clamps	Qty	Remarks
0	40	-	1	4	4	-	-	-	3	40	2		
1	40	1	-	-	-	-	-	-	3	40	2		
2	45	1	-	-	-	1	1	10	3	45	2		
3	45	1	-	-	-	-	-	-	3	45	2		
4	45	1	-	-	-	-	-	-	3	45	2		
5	45	1	-	-	-	-	-	-	3	45	2		
6	40	1	-	-	-	1	1	10	3	45	2		
7	45	1	-	-	-	-	-	-	3	40	2		
8	45	1	-	-	-	-	-	-	3	45	2		
9	45	1	-	-	-	1	1	10	3	45	2		
10	50	1	1	4	4	1	1	10	3	45	2		
11	45	1	1	4	4	-	-	-	2	50	-		
12	40	1	1	4	4	-	-	-	2	45	-		
13	40	1	1	4	4	1	1	10	2	40	-		
14	40	1	1	4	4	-	-	-	2	40	-		
15	40	1	1	4	4	1	1	10	2	40	-		
16	40	1	1	4	4	-	-	-	2	40	-		
17	45	1	1	4	4	1	1	10	2	45	-		
18	50	1	1	4	4	1	1	10	2	50	-		
19	45	1	1	4	4	-	-	-	2	45	-		
20	40	1	1	4	4	-	-	-	2	40	-		
21	40	1	1	4	4	1	1	10	2	40	-		
22	40	1	1	4	4	-	-	-	2	40	-		
23	40	1	1	4	4	-	-	-	2	40	-		
24	40	1	1	4	4	1	1	10	2	40	-		
	1070	24	16	64	64	10	10	100	60	1070	18	9	9

[Signature]
 JUNIOR ENGINEER
 I & D SECTION
 ELECTRICITY DEPARTMENT
 HAVELOCK