


**ELECTRICITY DEPARTMENT**
**Action: Commissioner-cum-Secretary (Power)/S.E (Power) / DSS / CE,PWD**

Island / Place	Demands / Points Raised	Reply / Proposed Action
Chowra	Enhancement of Power Supply duration at Chowra from existing 12 hours	<p>The scheme has been approved by CEA recently and is being notified. The scheme will be put up to SFC during June 2001. For increase of timing D.G Sets will be procured and installed and T&amp;D System shall be strengthened. APWD will renovate / extend the existing power house, cast new foundation and construct two quarters for additional staff required for the purpose which may take around 6-8 months. DSS shall provide suitable vessels for transporting of 50 tonnes HSD oil per month either from Port Blair or Kamorta and also a vessel for shifting of DG set and other materials from Katchal. However by shifting one 65 KW DG set from Katchal, 16 Hrs. power supply shall be provided from 15<sup>th</sup> August 2001.</p> <p><b>Action : SE (Elect) ; DSS</b></p>
	Improving low voltage in desalination plant for increased water supply.	<p>A.E, Electricity, Katchal shall lay an additional separate circuit from Power House to desalination plant.</p> <p><b>Action : SE (Electricity)</b></p>
	Loose overhead lines and joints in wires	<p>To be inspected in detail and set-right during the month of April 2001 itself.</p> <p><b>Action : SE (Electricity)</b></p>