

Pilopanja	Power Supply timings to be increased	As per approved scheme new DG sets will be added in next 4-5 months and power supply timings increased to 12hrs. / day. Action : SE, PWD)
	A big tree above the power house and quarter to be cut	The villagers agreed to cut the big tree just above the power house and quarters in next 15 days to avoid any damages to the buildings so as to avoid any disruption in power supply.
	Defective DG set to be repaired	An old DG set lying defective since a long to be repaired early or written off if it is no possible to repair it.
Campbell Bay	Refitting of removed Street Lights	Few SV street lights were removed earlier when these became non-functional. These will be repaired and refitted after repairs on getting materials from the Panchayats or new Street Lights fittings will be installed which will be provided by Panchayats. Action : SE (Electricity)
	Bills for monthly energy consumption to be raised as per meter readings	Non-functioning energy meters at consumers premises will be repaired / replaced and monthly bills raised as per meter readings. Action : SE (Electricity)
	Low voltage to be improved at 32 KM	Low voltage in this area will be improved by installing a transformer in next two months. Action : SE (Electricity)
	Street Lights to be provided on the road towards Rajiv Nagar	LT lines will be erected along the main road to Rajiv Nagar and street lights installed as required / provided by the Panchayat in next two months. Action : SE (Electricity)